



# BELLINGHAM FIRE DEPARTMENT

Life Safety Division  
1800 Broadway  
Bellingham, WA 98225  
360-778-8420

## HALON / CARBON DIOXIDE SYSTEMS CONFIDENCE TEST REPORT

ADDRESS: \_\_\_\_\_

BUSINESS: \_\_\_\_\_ DATE: \_\_\_\_\_

### SIX MONTH TEST

- Halon systems - Verified agent quantity and pressure in refillable containers. Yes [ ] No [ ]  
Original weight: \_\_\_\_\_ Original pressure: \_\_\_\_\_  
Current weight: \_\_\_\_\_ Current pressure: \_\_\_\_\_
- Carbon Dioxide systems - Verified agent quantity in refillable containers. Yes [ ] No [ ]  
Original weight: \_\_\_\_\_ Current weight: \_\_\_\_\_
- For either system, test results recorded on tag attached to cylinders. Yes [ ] No [ ]

### ANNUAL TEST

- Fire detection and activation systems tested using proper test procedures. Yes [ ] No [ ]
- Agent discharge piping inspected to confirm secure mounting. Yes [ ] No [ ]
- Agent discharge piping inspected to confirm it is free of any obstructions. Yes [ ] No [ ]
- System actuation properly operates all air handling, damper or door closer service to confine agent. Yes [ ] No [ ]
- Agent cylinders due for hydrostatic tests. Yes [ ] No [ ]

### GENERAL COMMENTS

Problems Found: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Corrections Made: \_\_\_\_\_  
\_\_\_\_\_

Correction date: \_\_\_\_\_ By: \_\_\_\_\_

This is to certify the halon/carbon dioxide (circle one) fire extinguishing system has been tested and inspected for reliability to cover the items listed in this report, is consistent with manufacturer's requirements, and all corrections have been made.

Signature of tester: \_\_\_\_\_

Agency: \_\_\_\_\_ Phone: \_\_\_\_\_

Copy Distribution: White – Fire Department Yellow – Premises Pink - Inspector