



NOTES:

- A. TRAIL DETAIL SHOWN DOES NOT INCLUDE STORMWATER DESIGN. STORMWATER DESIGN MUST BE COMPLETED IN ACCORDANCE WITH APPLICABLE CODES.
- B. DRAINAGE DITCH PARALLEL TO TRAIL MAY BE REQUIRED FOR STORMWATER DESIGN. MINIMUM DITCH WIDTH IS 3 FT. OR AS APPROVED BY PARKS MANAGER. SLOPE EACH SIDE OF CENTERLINE OF DITCH WITH MAXIMUM SIDE SLOPE OF 4H:1V OR AS OTHERWISE NOTED.
- C. WHERE TRAIL IS LOCATED OVER BURIED UTILITIES, THE ENTIRE UTILITY TRENCH SHALL BE BACKFILLED WITH IMPORTED GRAVEL AND COMPACTED TO 95% MAXIMUM DENSITY.
- D. SECTION SHOWN IS FOR TYPICAL CONDITIONS, TRAIL MAY BE MODIFIED TO ACCOMMODATE SITE SPECIFIC REQUIREMENTS.
- E. CRUSHED SURFACING BASE COURSE DEPTH AND SIZE OF AGGREGATE SHOWN IS MINIMUM REQUIREMENT. ACTUAL DEPTH OF AGGREGATE MAY VARY PER SITE SPECIFIC CONDITIONS.
- F. STAKE TRAIL ALIGNMENT AND TRAIL CLEARING LIMITS IN THE FIELD BEFORE CLEARING. VIOLATORS WILL BE FINED. SEE BMC13.40.150.
- G. SUBGRADE COMPACTION MUST BE CERTIFIED BY A GEOTECHNICAL ENGINEER.
- H. TRAIL WIDTH SHOWN IS MAXIMUM WIDTH. WIDTH MAY VARY ACCORDING TO SITE SPECIFIC PLAN.

PARKS AND RECREATION
 DESIGN AND DEVELOPMENT
 OCTOBER 19, 2011

CITY OF BELLINGHAM
 NARROW TRAIL
 Scale: NTS

DRAWING
 2505.02