



- NOTES:
- A. USE OF THIS DETAIL MAY NOT BE SUITABLE FOR ALL SITES AND MUST BE PREAPPROVED BY THE PARK PROJECT MANAGER.
 - B. CONCRETE SHALL BE MEDIUM BROOM FINISH. BROOM FINISH SHALL BE PERPENDICULAR TO THE PATH OF TRAVEL.
 - C. CONCRETE MIX DESIGN SHALL MEET WSDOT STANDARD SPECIFICATIONS, LATEST EDITION
 - D. NUMBER OF STEPS SHALL SUIT INDIVIDUAL CONDITIONS WITH UNIFORM TREAD AND RISER DIMENSIONS TO MEET REQUIREMENTS OF INTERNATIONAL BUILDING CODE, LATEST EDITION. THE MINIMUM TREAD DEPTH SHALL BE 12 INCHES
 - E. STEP WIDTH SHALL MATCH WIDTH OF WALKWAY, BUT SHALL BE NO LESS THAN 4'-0" WIDE
 - F. PROVIDE LANDINGS AS REQUIRED BY INTERNATIONAL BUILDING CODE, LATEST EDITION
 - G. REINFORCING STEEL SHALL BE ASTM A615 GR 60
 - H. TREAD SLOPES OUTWARD @1% IN DIRECTION OF TRAVEL
 - I. REPAIR OF GALVANIZED COATINGS SHALL IN ACCORDANCE WITH ASTM A 780 - 01

<p>PARKS AND RECREATION DESIGN AND DEVELOPMENT FEBRUARY 23, 2011</p>	<p>CITY OF BELLINGHAM CAST-IN-PLACE CONCRETE STAIR WITHOUT CONCRETE CURB WALL</p>	<p>DRAWING 03300.05</p>
---	--	------------------------------------