



NOTES:

- A. THIS DETAIL MAY NOT BE SUITABLE FOR ALL SITES AND MUST BE PRE-APPROVED BY THE PARK PROJECT MANAGER BEFORE USE.
- B. WHERE RAMPS AND STAIRS ARE INSTALLED, THEY SHALL MEET THE REQUIREMENTS OF MEANS OF EGRESS OF THE INTERNATIONAL BUILDING CODE (IBC), LATEST EDITION.
- C. LANDING WIDTH SHALL MATCH WIDTH OF WALKWAY, BUT SHALL BE NO LESS THAN 4'-0" WIDE. REFERENCE THE IBC FOR LANDING LENGTH REQUIREMENTS.
- D. PROVIDE LANDINGS AT INTERVALS REQUIRED BY THE INTERNATIONAL BUILDING CODE, LATEST EDITION.
- E. STEEL CONSTRUCTION SHALL BE IN ACCORDANCE WITH AISC, LATEST EDITION.
- F. ALL WELDS SHALL BE GROUND SMOOTH.
- G. HANDRAILS SHALL BE PREFABRICATED, SHOP WELDED, AND HOT DIP GALVANIZED BEFORE ARRIVING ON SITE.
- H. HOT DIP GALVANIZED REPAIRS SHALL BE COMPLETED IN ACCORDANCE WITH ASTM A780-01.

PARKS AND RECREATION  
 DESIGN AND DEVELOPMENT  
 FEBRUARY 23, 2011

CITY OF BELLINGHAM  
 METAL  
 HANDRAIL

DRAWING  
 05520.01