



DESIGN STANDARDS FOR: EXTERIOR LIGHTING

Building Lighting Standard:

1. Herculux model #H1212D series 5700 wall mount 100 watt HPS with external visor (part number 9081) manufactured by Kenall www.kenall.com, 847-360-8200.
2. Note: An approved equal will not be accepted. Sole source justification is based on bulk parts on hand; ease on maintenance time, availability, and vandal resistance.

Parking Lot Site Lighting Options (final option to be approved by Parks Project Manager):

1. Gardco Gullwing 18, 250W MH Lamp, 290 VA with round pole adapter on 5 inch diameter straight aluminum pole, 24ft 10 inches high with black finish. Top of foundation base to be 30 inches above finished grade.

or

2. Sterner Executive RT-25, 250 watt high pressure sodium lamp, with 25ft pole, square tapered steel pole with base plate "B" type mounting.
 - a. Catalog Number EXEC/RT25/250/HPS/3H/VOLT/C/10/N/N/BZ

Walkway Lighting Options (final option to be approved by Parks Project Manager):

1. Gardco Gullwing 13, 100W MH Lamp, 180 VA with round pole adapter on 4 inch diameter straight aluminum pole, 16ft high with black finish. Top of foundation base to be 2 inches above finished grade in lawn areas. Top of foundation to be flush with finished grade if located within finished concrete walkways.

Site Lighting Options:

1. Optional outlet at base where indicated by Park Project Manager

END OF SECTION