

Jason F Napier/fire/cob  
11/10/2008 11:56 AM

To JMoe@esassoc.com  
cc Kim W Weil/planning/cob@cob  
bcc  
Subject Fw: Fairhaven Highlands

Jill,

Here are the comments related to Response Times and Level of Service. I have highlighted them below.

I think that until I get a better picture of unit counts we have delivered everything that has been asked.

I look forward to assisting you as needed.

Take care,

D/C Jason Napier, CFM  
Fire Marshal

Bellingham Fire Department  
Life Safety Division  
Desk: 360-778-8422  
Fax: 360-778-8401  
Email: jnapier@cob.org


----- Forwarded by Jason F Napier/fire/cob on 11/10/2008 11:55 AM -----

William J Boyd/fire/cob  
11/10/2008 11:49 AM

To Jason F Napier/fire/cob@cob  
cc  
Subject Re: Fairhaven Highlands

I'm good with this. Thanks!

Bill Boyd, Fire Chief  
BELLINGHAM FIRE DEPARTMENT  
1800 Broadway  
Bellingham, Wa. 98225  
(360) 778-8400  
bboyd@cob.org  
Jason F Napier/fire/cob



Jason F Napier/fire/cob  
11/10/2008 10:23 AM

To William J Boyd/fire/cob@cob  
cc Kim W Weil/planning/cob@cob  
Subject Fairhaven Highlands

Chief,

This is a follow-up to my voice mail.

The consultant wants to determine the effects of the project on response time and level of service. Here are my thoughts, please let me know what you think.

**Response Time & Level of Service**

Level of Service and Response Times are interrelated. The fire department currently services the area around the undeveloped project area. The correct placement of access roadways into and within the project will be critical. The grades leading onto the property, under poor weather conditions, could significantly increase response times. The addition of more than 700 dwelling units to the community will increase the number of responses and will reduce the availability of Engine 2. In the event of simultaneous alarms, this will negatively impact the level of service since the next available units, from Station 3, have a greater distance to travel.

Thanks,

D/C Jason Napier, CFM  
Fire Marshal

Bellingham Fire Department  
Life Safety Division  
Desk: 360-778-8422  
Fax: 360-778-8401  
Email: [jnapier@cob.org](mailto:jnapier@cob.org)