

Hydrant Flow Test Report

Test Date 2/5/2013

Test Time 9:15 am

Location

University Ridge
44th St. & Consolidation Ave.
Bellingham WA 98225

Tested by

Commercial Fire Protection Inc.
17199 Bennett Rd.
Mt. Vernon WA 98273
360-848-9093

Notes

Flow at Hydrant #83323-05
Read at blow off #V83323-28
Hyd S=66 R=46
Level of water in tankl =452.2 ft.

Read Hydrant

58 psi static pressure
51 psi residual pressure
18.5 ft hydrant elevation

Flow Hydrant(s)

Outlet	Elev	Size	C	Pitot Pressure	Flow
#1	0	3.5	.93	24	1665 gpm

Flow Graph

