

- 2. PIPE ANCHORS SHALL BE PLACED SO THAT 1' OF THE ANCHOR WILL BE BELOW THE TRENCH LIMITS ON UNDISTURBED GROUND.
- CONCRETE ANCHORS SHALL BE PROVIDED WHEN REQUIRED PER WASHINGTON STATE DEPARTMENT OF ECOLOGY'S CRITERIA FOR SEWAGE WORKS DESIGN, LATEST EDITION, SECTION C1-4.4.

NOT TO SCALE

APPROVED CITY OF BELLINGHAM DRAWING SS-760 ZZ MAY 2023 PIPE ANCHOR Date City Engineer